

15.12.150 – Public buildings - Fire fighting appliances

Unless and until an approved sprinkler system is installed, the following appliances shall be required: the location and number of fire appliances shall be as follows, unless other location shall be more accessible and convenient for protection against fires:

A. Theaters.

1. Stage, two one-quart chemical hand extinguishers, one on each side of the stage; one two and one-half gallon chemical hand extinguisher, readily accessible; one five-gallon hand pump, one fire axe,
2. Foyer, two one-quart hand extinguishers at each end,
3. Manager's office, one two-gallon chemical hand extinguisher or five-gallon hand pump;

B. Public Buildings, Auditoriums, Lodge Halls, and Hotels.

1. Five-gallon hand pump and fire axe at or near the main entrance on the ground floor,
2. Five-gallon hand pump at or near the foot of all basement stairways,
3. Two pails in boiler room unless oil burner, then two and one-half gallon special chemical hand extinguishers just outside boiler room doors.
4. One-quart chemical hand extinguisher on the stage, and
5. One-quart chemical hand extinguisher in the lobby;

C. Churches.

1. One five-gallon hand pump and fire axe at or near main entrance on ground floor,
2. One five-gallon hand pump and fire axe in boiler room;

D. Schools.

1. One five-gallon hand pump and fire axe at or near the main entrance on ground floor,
2. One five-gallon hand pump and fire axe in boiler-room.

(Prior code : § 27.503)